



***Environmental, Planning, and Engineering Consultants***

34 South Broadway  
Suite 401  
White Plains, NY 10601  
tel: 914 949-7336  
fax: 914 949-7559  
[www.akrf.com](http://www.akrf.com)

## Memorandum

---

**To:** Village of Mamaroneck Planning Board  
**From:** Ashley Ley, AICP  
**Date:** January 20, 2022  
**Re:** 921 Soundview  
**cc:** Jaclyn Tyler – Nexus Creative, Teresa Bakner, Esq., Kellard Sessions, Brittanie O’Neil

---

AKRF, Inc. has reviewed the following application materials for the above-referenced project:

- Site Survey, prepared by Richard Spinelli, dated 9/7/21
- Engineering Drawing Set (5 sheets), prepared by ALP Engineering, dated 10/18/21 and last revised 12/29/21
- Schematic House Study Drawing Set (12 sheets), prepared by Nexus Architecture Planning Design, dated 12/29/21
- Building Determination, dated 6/9/21
- Building Permit Application Form
- Planning Board Application Form, dated 1/3/22
- Wetland Permit Application Form, dated
- Short EAF, dated 5/14/21
- Stormwater Pollution Prevention Plan, prepared by Alan L Pilch, dated 12/29/21

### PROJECT DESCRIPTION

The applicant proposes a new single-family residence and pool on an approximately 0.52 acre lot located in the R-10 Zoning District at 921 Soundview Drive, Mamaroneck, NY. The project requires site plan and wetland permit approval from the Planning Board and HCZMC LWRP Consistency Review.

### COMMENTS

1. The acreage listed on the Planning Board Application is provided as 22,999 square feet, 0.0528 acres. This should have stated 0.528 acres. The Short EAF lists the acreage as 0.554 +/- acres. The acreages should be corrected for consistency and should also be included on the survey.
2. The NYSDEC freshwater wetland line should be included on the drawings. If the prior wetland delineation was verified by NYSDEC, that should be indicated. If not, the site will likely require a jurisdictional determination.

3. To minimize wetland buffer disturbance and shading, the Applicant should consider rotating the pool 90 degrees, eliminating the open space within the decking, and reducing the overall size of the deck.
4. A public hearing is required for wetland permits. AKRF recommends that this be set when Applicant returns from the HCZMC.
5. AKRF, Inc. has reviewed the application materials in relation to the requirements of Chapter 300 of the Village Code. The following table summarizes the status of each requirement and identifies where additional information is necessary for site plan review.

Code Reference	Code Requirement	Status
§ 300-2	Enclosure; fence.	
	Every outdoor private swimming pool which is built in ground or, if above ground, has a permanent, nonremovable, attached ladder shall be completely enclosed by a fence of durable construction or other suitably effective enclosure not less than four (4) feet in height. A dwelling house or accessory building may be used as a part of such enclosure. Any opening or mesh in the fence as finally constructed shall be no greater than sixteen (16) square inches in area, except that, in case of a picket fence, space between pickets shall not exceed four (4) inches. Every gate of such fence shall be self-closing and shall be kept securely locked at all times.	Provided. See sheets A-4 and A-7 of architectural drawings and sheet C-101 in the Engineering Drawings.
§ 300-3	Prohibitions and standards.	
A.	No pool shall be erected or constructed in the front yard of any premises.	Compliant. Pool is proposed in the backyard.
B.	No pool or its appurtenances, including but not limited to its filter and heater, shall be erected or constructed on any lot closer than six (6) feet to the rear property line, with side yard setbacks as prescribed by the Schedule of Minimum Requirements for Residential Districts, Chapter 342, Zoning, or, in the case of a corner lot, no closer than ten (10) feet to any property line along an abutting street.	Compliant. See sheets A-0.1 and A-0.2 of architectural drawings and sheet C-101 in the Engineering Drawings.
C.	No pool shall occupy more than forty percent (40%) of the area of the rear yard, exclusive of all garages or other accessory structures located in such area.	Not provided. This calculation should be added to sheet C-101.
D.	All electrical and plumbing work shall be done by persons licensed by the Village of Mamaroneck. Where applicable, approval of the New York State Board of Fire Underwriters shall be obtained and filed.	This is a building permit requirement and not applicable to site plan review.
E.	The location of the pool shall be such that it will not adversely affect any neighboring premises, property or structures.	The proposed pool would be located in the rear yard and within the required setbacks.
F.	The lighting provided shall be installed in such a way that it will not create a nuisance or annoyance to adjoining property owners.	Lighting plan not provided. A lighting plan including fixture details

		and photometrics should be provided.
G.	Suitable screening and/or landscaping, at a minimum height of four (4) feet, shall be provided between the instant premises and all adjacent properties or streets.	No screening or landscaping is indicated on the drawings. If any is proposed, it should be added to a drawing. Given the elevated nature of the pool, screening on the ground may be insufficient.
H.	All equipment shall be so constructed that it may be used without causing any discomfort or disturbance to persons residing adjacent to or near the pool.	The proposed location of equipment and associated screening should be added to sheet A-0.2 of the architectural drawings and sheet C-101 of the engineering drawings.
I.	In all other respects, the pool shall be free from any objection on the grounds of safety or health and welfare of the community and the surrounding neighborhood in particular, and it shall comply with the provisions of the Sanitary Code of the County of Westchester and the Sanitary Code established by the Public Health Council of the State of New York so far as any of the provisions of such code may be applicable.	This is a building permit requirement.
J.	The Building Inspector may impose such reasonable conditions as he deems proper to assure neighboring properties and owners that their health and safety and peace and comfort will be protected.	This is a building permit requirement.
§ 300-4.	Application for permit; required data.	
A.	A profile showing levels and depths of water at all points.	This information should be added to sheet A-4 of the architectural drawings (or added to another suitable drawing).
B.	Cross sections showing scum gutters and skimmers with all structural details.	Not provided.
C.	A pipe diagram showing size and location of all inlets, outlets, waterlines, waste and discharge lines, circulation and other piping.	This is a building permit requirement.
D.	Pool equipment showing detail and location of filters, pumps, chlorinators, strainers and hair and lint interceptors.	This is a building permit requirement.
E.	Drains and drainage from the pool structure to a sanitary sewer.	This is a building permit requirement.

F.	Pool to be filled with an over-the-lip spout above the overflow level of the pool so that there is no chance of water from the pool siphoning back into the fill line.	This is a building permit requirement.
G.	A site plan showing the proposed location of the pool, all accessory equipment, fences, screening and landscaping, accessory buildings and any other items deemed to be pertinent by the Building Inspector.	Some information not provided. Accessory equipment, fences, screening, and landscaping should be indicated on Sheet C-101 of the engineering drawings.

**RECOMMENDED ACTIONS**

At the January 26, 2022 meeting, AKRF recommends that the Planning Board classify the project as a Type II Action under SEQRA and refer it to the HCZMC.