

Daniel Sarnoff

From: Jeff Ahne
Sent: Thursday, January 11, 2024 12:45 PM
To: Daniel Sarnoff
Cc: Jerry Barberio; Chief Sandra DiRuzza
Subject: Fwd: Mamaroneck High School Signal

Dan

Please see email below

They have to separate the power and signal lines anyway so it makes sense to put in a generator transfer switch this way the village can hook up a small generator to light and still have it operational for future weather events and black outs

Thanks Jeff
Sent from my iPhone

Begin forwarded message:

From: Richard DiLeonardo <rdileonardo@verdeelectric.com>
Date: January 11, 2024 at 11:10:45 AM EST
To: Jeff Ahne <jahne@vomny.org>
Cc: Robert Craig <rcraig@verdeelectric.com>, Tricia Lillo <tlillo@verdeelectric.com>
Subject: Mamaroneck High School Signal

Jeff,

While onsite our crew discovered that the power service and signal cable are intermingled in the signal pole. With the new service riser Verde recommends installing a generator transfer switch which will provide for a means of power disconnect prior to the controller cabinet, secondly it provides the Village with the capability to power the signal during unexpected outages. The adder to this work will be \$2,200.00 .

Richard DiLeonardo
Project Manager

The Verde Group

89 Edison Ave
Mt. Vernon, N.Y 10550
Phone: (914) 664-7000
Mobile: (914) 804-3377
Fax: (914) 668-7997



www.verdeelectric.com